

COMPARISON OF December 2012 FINAL to December 2011 Reproposal and FINAL March 2011 BOILER MACT LIMITS and June 2010 PROPOSED BOILER MACT LIMITS

HAP/Fuel	Proposal	Final	Re-proposal	Dec-12	Factor Better	Proposal	Final	Re-proposal	Dec-12	Factor Better	Units	Output Based (lb/MMBtu steam output) - March 2011 to Dec 2012				
	Existing Boilers					New Boilers						Existing	Dec-12	New	Dec-12	
Hg Biomass	0.9	4.6	3.1	5.7	1.8	0.2	3.5	0.86	0.8	0.9	lb/TBtu	4.5	6.4	3.4	0.87	
PM Biomass	0.02	0.039	multiple	multiple	below	0.008	0.0011	multiple	multiple	NA	lb/MMBtu	0.038	multiple	0.0011	multiple	
HCl Biomass	0.006	0.035	0.022	0.022	1.0	0.004	0.0022	0.022	0.022	1.0	lb/MMBtu	0.04	0.025	0.0021	0.025	
Hg Coal	3	4.6	3.1	5.7	1.8	2	3.5	0.86	0.8	0.9	lb/TBtu	4.5	6.4	3.4	0.87	
PM Coal	0.02	0.039	multiple	multiple	below	0.001	0.0011	multiple	multiple	below	lb/MMBtu	0.038	multiple	0.0011	multiple	
HCl Coal	0.02	0.035	0.022	0.022	1.0	0.00006	0.0022	0.022	0.022	1.0	lb/MMBtu	0.04	0.025	0.0021	0.025	
Hg Oil	4	3.5	26	2.0	0.1	0.3	0.21	0.49	0.48	1.0	lb/TBtu	3.3	2.5	0.2	0.53	
Hg Oil non-continental	4	0.78	26	2.0	0.1	0.3	0.78	0.49	0.48	1.0	lb/TBtu	0.8	2.5	0.8	0.53	
PM Oil	0.004	0.0075	multiple	multiple	below	0.002	0.0013	multiple	multiple	NA	lb/MMBtu	0.0073	multiple	0.001	multiple	
HCl Oil	0.0009	0.00033	0.0012	0.0011	0.9	0.0004	0.0032	0.0012	0.00044	0.4	lb/MMBtu	0.003	1.40E-03	0.003	4.80E-04	
Hg Gas 2	0.2	13	7.9	7.9	1.0	0.2	7.9	7.9	7.9	1.0	lb/TBtu	7.8	14	0.2	14	
PM Gas 2	0.05	0.043	0.0067	0.0067	1.0	0.003	0.0067	0.0067	0.0067	1.0	lb/MMBtu	0.026	0.012	0.004	0.012	
HCl Gas 2	0.000003	0.0017	0.0017	0.0017	1.0	0.000003	0.0017	0.0017	0.0017	1.0	lb/MMBtu	0.001	0.0029	0.003	0.0029	
Or clean gas 2 can opt in to Gas 1 work practice if:	NA	Hg content <40 ug/m3					NA	Hg content <40 ug/m3								
Short-term/3 hour test	Existing Boilers					New Boilers						Existing	Dec-12	New	Dec-12	
CO Biomass Wet Stoker/Sloped Grate/Other	560	490	790	1500	1.9	560	160	590	620	1.1	ppm at 3%O2	0.35	1.4	0.13	0.58	
CO Biomass Kiln-Dried Stoker/Sloped Grate/Other	560	490	250	460	1.8		160	250	460	1.8	ppm at 3%O2		0.42		0.42	
CO Biomass FB	250	430	370	470	1.3	40	260	230	230	1.0	ppm at 3%O2	0.28	0.46	0.18	0.22	
CO Biomass Dutch/Pile	1010	470	810	770	1.0	1010	470	810	330	1.7	ppm at 3%O2	0.45	0.84	0.45	0.35	
CO Biomass Suspension Burner	1010	470	58	2400	41.4	NA	NA	58	2400	NA	ppm at 3%O2	0.45	1.9	0.45	1.9	
CO Biomass Fuel Cell	270	690	1500	1100	0.7	270	470	210	910	4.3	ppm at 3%O2	0.34	2.4	0.23	1.1	
CO Biomass Hybrid Suspension/ Grate	NA	3500	3900	2800	0.7	NA	1500	1500	1100	0.7	ppm at 3%O2	2	2.8	0.84	1.4	
CO Coal pulverized	90	160	41	130	3.2	90	12	9	130	14.4	ppm at 3%O2	0.14	0.11	0.01	0.11	
CO Coal stoker	50	270	220	160	0.7	7	6	19	130	6.8	ppm at 3%O2	0.25	0.14	0.005	0.12	
CO Coal FB	30	82	56	130	2.3	30	18	17	130	7.6	ppm at 3%O2	0.08	0.12	0.02	0.11	
CO Coal FBHE				140					140				0.13		0.12	
CO Oil - Heavy	1	10	10	130	13.0	1	3	10	130	13.0	ppm at 3%O2	0.0083	0.13	0.0026	0.13	
CO Oil - Light	1	10	7	130	18.6	1	3	3	130	43.3	ppm at 3%O2	0.0083	0.13	0.0026	0.13	
CO Oil non-continental	1	160	18	130	7.2	1	51	18	130	7.2	ppm at 3%O2	0.13	0.13	0.043	0.13	
CO Gas2	1	9	4	130	32.5	1	3	4	130	32.5	ppm at 3%O2	0.005	0.16	0.002	0.16	
Long-term CEMS limit (30 day avg except as noted)				30 day except as noted					30 day except as noted							
CO Biomass Wet Stoker/Sloped Grate/Other	NA	NA	410	720	1.8	NA	NA	410	390	1.0	ppm at 3%O2					
CO Biomass Kiln-Dried Stoker/Sloped Grate/Other	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	ppm at 3%O2					
CO Biomass FB	NA	NA	180	310	1.7	NA	NA	180	310	1.7	ppm at 3%O2					
CO Biomass Fuel Cell	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	ppm at 3%O2					
CO Biomass Suspension Burner	NA	NA	1400	2000 (10 day)	1.4	NA	NA	1400	2000 (10 day)	1.4	ppm at 3%O2					
CO Biomass Dutch/Pile	NA	NA	440	520 (10 day)	1.2	NA	NA	440	520 (10 day)	1.2	ppm at 3%O2					
CO Biomass Hybrid Suspension/ Grate	NA	NA	730	900	1.2	NA	NA	730	900	1.2	ppm at 3%O2					
CO Coal stoker	NA	NA	34	340	10.0	NA	NA	34	340	10.0	ppm at 3%O2					
FB with heat exchanger				150	NA				150	NA						
CO Coal FB	NA	NA	59	230	3.9	NA	NA	59	230	3.9	ppm at 3%O2					
CO Coal pulverized	NA	NA	28	320	11.4	NA	NA	28	320	11.4	ppm at 3%O2					
CO Oil - Heavy	NA	NA	18	na	NA	NA	NA	18	na	NA	ppm at 3%O2					
CO Oil - Light	NA	NA	60	na	NA	NA	NA	60	na	NA	1 day block average					
CO Oil non-continental	NA	NA	91	na	NA	NA	NA	91	na	NA	3 hour rolling average					
HAP/Fuel	Proposal	Final	Re-proposal	Dec-12	Factor Better	Proposal	Final	Re-proposal	Dec-12	Factor Better	Units	Output Based (lb/MMBtu steam output) - March 2011 to December 2012				
Existing Boilers					New Boilers						Existing	Dec-12	New	Dec-12		
D/F Biomass stoker	0.004	0.005	work practice	work practice	NA	0.00005	0.005	work practice	work practice	NA	ng/dscm at 7%O2	4.40E-12	work practice	4.40E-12	work practice	
D/F Biomass FB	0.004	0.02	work practice	work practice	NA	0.007	0.02	work practice	work practice	NA	ng/dscm at 7%O2	1.80E-11	work practice	1.80E-11	work practice	
D/F Biomass Dutch Oven	0.03	0.2	work practice	work practice	NA	0.03	0.2	work practice	work practice	NA	ng/dscm at 7%O2	1.80E-10	work practice	1.80E-10	work practice	
D/F Biomass Suspension Burner	NA	NA	work practice	work practice	NA	NA	NA	work practice	work practice	NA	NA	NA	work practice	NA	work practice	
D/F Biomass Fuel Cell	0.02	4	work practice	work practice	NA	0.0005	0.003	work practice	work practice	NA	ng/dscm at 7%O2	3.50E-09	work practice	2.86E-12	work practice	
D/F Biomass Hybrid Suspension/Grate	NA	0.2	work practice	work practice	NA	NA	0.2	work practice	work practice	NA	ng/dscm at 7%O2	1.80E-10	work practice	1.80E-10	work practice	

COMPARISON OF December 2012 FINAL to December 2011 Reproposal and FINAL March 2011 BOILER MACT LIMITS and June 2010 PROPOSED BOILER MACT LIMITS

	0.004	0.004	work practice	work practice	NA	0.002	0.003	work practice	work practice	NA	ng/dscm at 7%O2	3.70E-12	work practice	2.80E-12	work practice							
D/F Coal pulverized	0.004	0.004	work practice	work practice	NA	0.002	0.003	work practice	work practice	NA	ng/dscm at 7%O2	3.70E-12	work practice	2.80E-12	work practice							
D/F Coal stoker	0.003	0.003	work practice	work practice	NA	0.003	0.003	work practice	work practice	NA	ng/dscm at 7%O2	2.80E-12	work practice	2.80E-12	work practice							
D/F Coal FB	0.002	0.002	work practice	work practice	NA	0.00003	0.002	work practice	work practice	NA	ng/dscm at 7%O2	1.80E-12	work practice	1.80E-12	work practice							
D/F Oil	0.002	4	work practice	work practice	NA	0.002	0.002	work practice	work practice	NA	ng/dscm at 7%O2	9.20E-09	work practice	4.60E-12	work practice							
D/F Gas2	0.009	0.08	work practice	work practice	NA	0.009	0.08	work practice	work practice	NA	ng/dscm at 7%O2	3.90E-11	work practice	4.10E-12	work practice							
	Proposal	Final	Re-proposal	Dec-12	Factor Better	Proposal	Final	Re-proposal	Dec-12	Factor Better	Units	Output Based (lb/MMBtu steam output) - March 2011 to December 2012				Existing				New		
	Proposal	Final	Re-proposal	Dec-12	Factor Better	Proposal	Final	Re-proposal	Dec-12	Factor Better	Units	Existing	Dec-12	New	Dec-12	TSM. lb/MMBtu 2004	TSM. lb/MMBtu Reprop	TSM. lb/MMBtu Dec-12	Factor Better	Output Based lb/MMBtu steam Dec-12	TSM. lb/MMBtu Dec-12	Output Based lb/MMBtu steam Dec-12
Existing Boilers						New Boilers																
PM Biomass Wet Stoker/Sloped Grate/Other	0.02	0.039	0.029	0.037	1.3	lb/MMBtu	0.001	0.029	0.03	1.0	lb/MMBtu	0.35	0.043	0.13	0.035	0.001	5.7E-05	2.4E-04	4.21	2.8E-04	2.6E-05	2.7E-05
PM Biomass Kiln-Dried Stoker/Sloped Grate/Other	0.02	0.039	0.32	0.32	1.0	lb/MMBtu	0.001	0.32	0.03	0.1	lb/MMBtu	0.35	0.37	0.13	0.035	0.001	4.0E-03	4.0E-03	1.00	4.6E-03	4.0E-03	4.2E-03
PM Biomass FB	0.02	0.039	0.11	0.11	1.0	lb/MMBtu	0.001	0.0098	0.0098	1.0	lb/MMBtu	0.28	0.14	0.18	0.012	0.001	1.2E-03	1.2E-03	1.00	1.5E-03	8.3E-05	1.1E-04
PM Biomass Dutch/Pile	0.02	0.039	0.036	0.26	7.8	lb/MMBtu	0.001	0.036	0.0032	0.1	lb/MMBtu	0.45	0.39	0.45	0.0043	0.001	2.4E-04	2.0E-03	8.33	2.8E-03	3.9E-05	5.2E-05
PM Biomass Suspension Burner	0.02	0.039	0.051	0.051	1.0	lb/MMBtu	0.001	0.051	0.03	0.6	lb/MMBtu	0.45	0.052	0.45	0.031	0.001	1.1E-03	6.5E-03	5.91	6.6E-02	6.5E-03	6.6E-03
PM Biomass Fuel Cell	0.02	0.039	0.033	0.020	0.6	lb/MMBtu	0.001	0.011	0.02	1.8	lb/MMBtu	0.34	0.055	0.23	0.03	0.001	4.9E-05	5.8E-03	118.37	1.6E-02	2.9E-05	5.1E-05
PM Biomass Hybrid Suspension/ Grate	0.02	0.039	0.44	0.44	1.0	lb/MMBtu	0.001	0.026	0.026	1.0	lb/MMBtu	2	0.55	0.84	0.033	0.001	4.9E-04	4.5E-04	0.92	5.7E-04	4.4E-04	5.5E-04
PM Coal pulverized	0.02	0.039	0.044	0.040	0.9	lb/MMBtu	0.001	0.0013	0.0011	0.8	lb/MMBtu	0.14	0.042	0.01	0.0011	0.001	5.9E-05	5.3E-05	0.90	5.6E-05	2.3E-05	2.7E-05
PM Coal stoker	0.02	0.039	0.028	0.040	1.4	lb/MMBtu	0.001	0.028	0.0011	0.0	lb/MMBtu	0.25	0.042	0.005	0.0011	0.001	8.3E-05	5.3E-05	0.64	5.6E-05	2.3E-05	2.7E-05
PM Coal FB	0.02	0.039	0.088	0.040	0.5	lb/MMBtu	0.001	0.0011	0.0011	1.0	lb/MMBtu	0.08	0.042	0.02	0.0011	0.001	1.7E-05	5.3E-05	3.12	5.6E-05	2.3E-05	2.7E-05
PM Oil - heavy	0.004	0.0075	0.062	0.062	1.0	lb/MMBtu	0.0013	0.013	0.013	1.0	lb/MMBtu	0.0083	0.075	0.0026	0.015				NA	2.5E-04	7.5E-05	8.2E-05
PM Oil - light	0.004	0.0075	0.0034	0.0079	2.3	lb/MMBtu	0.0013	0.0011	0.0011	1.0	lb/MMBtu	0.0083	9.60E-03	0.0026	0.0012				NA	7.5E-05	2.9E-05	3.2E-05
PM Oil non-continental	0.004	0.0075	0.008	0.27	33.8	lb/MMBtu	0.0013	0.008	0.023	2.9	lb/MMBtu	0.13	0.33	0.043	0.025				NA	1.1E-03	8.6E-04	9.4E-04
PM Gas2	0.05	0.043	0.0067	0.0067	1.0	lb/MMBtu	0.0067	0.0067	0.0067	1.0	lb/MMBtu	0.005	0.012	0.002	0.012	NA	2.4E-04	2.1E-04	0.88	3.5E-04	2.1E-04	3.5E-04

Follow work practices during periods of startup and shutdown. Startup and Shutdown are defined, work practice requirements are specified.